

JHARKHAND EDUCATION PROJECT, HAZARIBAGH

Drinking Water Testing Report

Name of School :- DELHI PUBLIC SCHOOL HAZARIBAGH

Block:- SADAR

Sample No.-

Sample Collected Date:- 20/11/21

Sample Analysis Date:- 20/11/21

Parameter	Normal Range	Test Result
Taste		
BIS Standard Limit		
Turidity (NTU)	1 - 5	NO
Ph Value	6.5-8.5	7.0
Alkalinity(Mg/l)	200-600	250
Chloride(Mg/l)	250-1000	100
Iron (Mg/l)	0.3-1	0
Hardness	200-600	250
Fluride(Mg/l)	1.0-1.5	0.5
TDS	600-2000	720
Nitrate (NITRIE)	0-45	0

Remarks:- POTABLE

Junior Engineer

Jharkhand Education Project,
Hazaribagh

PRINCIPAL
DELHI PUBLIC SCHOOL
HAZARIBAGH (JHARKHAND)

Assistant Engineer

Jharkhand Education Project
Hazaribagh

MANAGER
DELHI PUBLIC SCHOOL
HAZARIBAGH (JHARKHAND)